

**For Use With Fire Dept Valve, 2 1/2" Fire Dept Valve & Fire Extinguisher**

Series 1750 and 1770 cabinets will accommodate Fire Dept Valves, 1 1/2" and or 2 1/2" size with caps and chain and a portable Fire Extinguisher.



1750 Series



1770 Series

**STANDARD EQUIPMENT**

- \* Heavy gauge steel construction tub, door and trim
- \* White powder coat finish
- \* Continuous steel piano hinge
- \* Pull handle with roller catch

**CABINET OPTIONS**

- \* Prefix **FR** for Fire Rated Cabinet
- \* Suffix **AL** for clear anodized aluminum door and frame
- \* Suffix **SS** for Stainless Steel # 4 finish door and frame
- \* Suffix **FF** for Detention Grade Heavy Steel Door And Trim
- \* Door Styles See page 2-6
- \* Other cabinet options See page 2-7, 2-19 and 2-20

**ORDERING PROCEDURE**

- \* Select cabinet Figure No.
- \* Select door style
- \* Select Fire Dept Valve with Cap and Chain (Refer to Section 5000)
- \* Select type and size of Fire Extinguisher

FIGURE #	TRIM STYLE	Trim Poj. Tp	Valve Cap.	Inside box dimensions			Overall outside dim		Knockout locations				Wall Opening Required			FIRE RATED CABINETS Wall Opening Required FR Option		
				A	B	C	D	E	J	K	M	N	Width	Height	Depth	Width	Height	Depth
1750	Recessed	5/16"	1 1/2 or 2 1/2	20	27	7 3/4	23 3/8	30 3/8	4	4	4	4	21	28	7 7/8	22	29 1/8	8 1/2
1751	Semi-recessed	1 1/4"		20	27	7 3/4	23 3/8	30 3/8	4	4	4	4	21	28	6 3/4	22	29 1/8	7 3/8
1752	Semi-recessed	2 1/2"		20	27	7 3/4	23 3/8	30 3/8	4	4	4	4	21	28	5 1/2	22	29 1/8	6 3/8
1754	Semi-recessed	4 1/2"		20	27	7 3/4	23 3/8	30 3/8	4	4	4	4	21	28	3 1/2	22	29 1/8	4 1/8
1758	Surface			23 3/16	30 3/16	8 1/4	23 3/8	30 3/8	4	4	4	4						
1770	Recessed	3/8"	1 1/2 or 2 1/2	16	40	9	19 3/8	43 3/8	6	4 1/4	6	4 1/4	17	41	9	18	42 1/8	10
1771	Semi-Recessed	1 1/4"		16	40	9	19 3/8	43 3/8	6	4 1/4	6	4 1/4	17	41	8 1/8	18	42 1/8	9 1/8
1772	Semi-Recessed	2 1/2"		16	40	9	19 3/8	43 3/8	6	4 1/4	6	4 1/4	17	41	6 5/8	18	42 1/8	7 1/2
1776	Trimless			16	40	9	16 1/4	40 1/4	6	4 1/4	6	4 1/4	16 1/2	40 1/2	9 1/4			
1778	Surface			19 3/16	43 3/16	9 1/2	19 3/8	43 3/8	a	a	a	a						

a- No knockouts provided unless specified on surface mounted cabinets  
 Note: Add 5/8" to depth of wall opening required for cabinets with aluminum frame  
 Note: If 2 1/2" x 1 1/2" reducing adapter is used for Fire Dept Valve "C" dimension should be no less than 10".

\* Trimless, recessed and semi-recessed cabinets furnished with combination knockouts (1 1/2" and 2 1/2" on both sides)  
 NOTE: FIRE RATED CABINETS HAVE NO KNOCKOUTS

